

APPENDIX 5 – Leak History Data

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
1A	3	UNK	25	0	0	0	0	8,976	0.0	0.0000	0.0	132
	4	ACP	136	0	0							
	6	ACP	7,532	0	0							
	8	ACP	1,857	0	0							
1B	8	UNK	125	0	0	0	0	6,600	0.0	0.0000	0.0	132
	4	ACP	162	0	0							
	6	ACP	2,882	0	0							
	6	DIP	14	0	0							
	8	ACP	2,013	0	0							
	8	DIP	632	0	0							
1C	8	PVC	359	0	0	0	0	10,560	0.0	0.0000	0.0	132
	12	ACP	312	0	0							
	4	ACP	65	0	0							
	5	UNK	8	0	0							
	6	ACP	7,642	0	0							
2A	8	ACP	2,292	0	0	4	0	37,488	2.0	0.0002	7.5	64
	8	DIP	463	0	0							
	4	DIP	59	0	0							
	6	ACP	1,137	0	0							
	6	PVC	827	2	0							
	8	DIP	10,276	0	0							
	8	PVC	7,173	2	0							
2B	12	DIP	11,861	0	0	0	0	22,176	0.0	0.0000	0.0	132
	12	PVC	17,186	0	0							
	6	DIP	216	0	0							
	8	DIP	5,255	0	0							
	8	PVC	1,551	0	0							
2C	10	PVC	4	0	0	0	0	24,816	0.0	0.0000	0.0	132
	12	DIP	10,989	0	0							
	12	PVC	8,866	0	0							
	4	DIP	12	0	0							
	6	DIP	767	0	0							
	8	DIP	10,499	0	0							
	8	PVC	1,299	0	0							
2D	12	CIP	13	0	0	4	0	27,456	2.0	0.0002	5.5	75
	12	DIP	5,648	0	0							
	12	PVC	6,745	0	0							
	4	DIP	41	0	0							
	4	PVC	30	0	0							
	6	DIP	2,628	0	0							
	6	PVC	638	3	0							
	8	DIP	17,185	1	0							
	8	PVC	137	0	0							
2E	12	CIP	17	0	0	0	0	26,928	0.0	0.0000	0.0	132
	12	DIP	13,166	0	0							
3A	12	DIP	8,553	0	0	0	25	31,680	25.0	0.0025	79.2	6
	12	PVC	1,775	0	0							
	8	DIP	13,969	0	0							
	12	DIP	13,166	0	0							
	4	ACP	578	0	1							
	6	ACP	1,673	0	2							
	8	ACP	24,829	0	22							
	8	DIP	182	0	0							
3B	8	PVC	672	0	0	0	16	21,648	16.0	0.0016	34.6	20
	10	ACP	495	0	0							
	10	CIP	579	0	0							
	12	DIP	5,198	0	0							
	12	PVC	152	0	0							
	12	UNK	2	0	0							
	12	DIP	2,762	0	1							
	12	PVC	18	0	0							
4	8	PVC	57	0	0	4	18	44,880	20.0	0.0020	89.8	4
	8	DIP	671	0	0							
	8	ACP	23,364	0	15							
	6	DIP	15	0	0							
	6	ACP	21,544	3	12							
	6	DIP	15	0	0							
	8	ACP	23,939	1	5							
	8	DIP	84	0	0							
4	10	ACP	71	0	0	4	18	44,880	20.0	0.0020	89.8	4
	12	DIP	2,998	0	0							
	12	UNK	41	0	0							
	12	PVC	28	0	0							
	12	PVC	28	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
5A	4	ACP	2,129	0	0	0	4	43,296	4.0	0.0004	17.3	44
	6	ACP	10,649	0	1							
	6	DIP	80	0	0							
	8	ACP	10,952	0	0							
	8	DIP	65	0	0							
	8	PVC	1,805	0	0							
	10	ACP	4,820	0	2							
	12	ACP	6,186	0	0							
	12	CIP	171	0	0							
	12	DIP	347	0	0							
	12	PVC	6,077	0	1							
	14	ACP	37	0	0							
14	CIP	114	0	0								
5B	8	ACP	48	0	0	7	1	42,240	4.5	0.0005	19.0	41
	8	PVC	17,479	1	0							
	12	ACP	671	0	0							
	12	DIP	570	0	1							
5C	12	PVC	22,306	6	0	5	0	44,880	2.5	0.0003	11.2	56
	5	UNK	177	0	0							
	6	ACP	377	0	0							
	6	DIP	386	0	0							
	8	ACP	11,405	0	0							
	8	DIP	2,388	0	0							
	8	PVC	8,204	4	0							
	10	ACP	187	0	0							
	12	ACP	11,305	0	0							
	12	DIP	2,799	0	0							
6A	12	PVC	7,953	1	0	2	9	21,384	10.0	0.0010	21.4	35
	4	ACP	2,276	0	2							
	6	ACP	15,286	2	4							
	8	ACP	7,841	0	3							
	8	DIP	122	0	0							
	12	DIP	154	0	0							
6B	12	PVC	26	0	0	0	5	22,176	5.0	0.0005	11.1	57
	4	ACP	18	0	0							
	6	ACP	14,759	0	4							
	8	ACP	4,886	0	1							
6C	10	ACP	133	0	0	0	4	19,008	4.0	0.0004	7.6	62
	4	ACP	5,561	0	2							
	6	ACP	11,624	0	2							
	6	DIP	6	0	0							
	8	ACP	4,604	0	0							
	8	DIP	28	0	0							
6D	12	DIP	0	0	0	0	16	22,704	16.0	0.0016	36.3	17
	4	ACP	8,869	0	11							
	6	ACP	10,551	0	3							
	6	CIP	25	0	0							
	6	DIP	47	0	0							
	8	ACP	3,906	0	2							
	8	DIP	279	0	0							
6E	12	DIP	3	0	0	0	7	21,120	7.0	0.0007	14.8	50
	4	ACP	1,509	0	0							
	6	ACP	17,822	0	5							
	6	CIP	30	0	0							
	8	ACP	4,321	0	2							
6F	8	DIP	142	0	0	1	5	9,504	5.5	0.0006	5.2	77
	4	ACP	4,687	1	4							
	4	ODS	71	0	0							
	6	ACP	4,631	0	1							
	6	DIP	9	0	0							
	8	ACP	376	0	0							
6G1	8	DIP	229	0	0	0	6	10,011	6.0	0.0006	6.0	70
	12	DIP	138	0	0							
6G2	4	ACP	3,919	0	3	0	2	1,575	2.0	0.0002	0.3	126
	6	ACP	5,182	0	3							
	4	ACP	613	0	0							
6H	8	DIP	465	0	0	0	2	8,448	2.0	0.0002	1.7	105
	4	ACP	338	0	1							
	6	ACP	428	0	1							
	6	DIP	9	0	0							
	8	ACP	109	0	0							
	8	DIP	14,250	0	0							
12	DIP	10,118	0	0								

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
6I	4	ACP	4,731	1	7	2	12	12,672	13.0	0.0013	16.5	48
	6	ACP	7,078	0	5							
	8	ACP	3,110	1	0							
	8	DIP	171	0	0							
	8	PVC	125	0	0							
6J	12	DIP	26	0	0	0	7	8,976	7.0	0.0007	6.3	69
	4	ACP	5,327	0	5							
	6	ACP	5,572	0	2							
	8	ACP	4	0	0							
	8	DIP	1,537	0	0							
6K	8	PVC	130	0	0	2	10	20,064	11.0	0.0011	22.1	34
	12	DIP	127	0	0							
	4	ACP	6,997	1	8							
	6	ACP	7,736	1	0							
	8	ACP	3,074	0	2							
6M	8	PVC	1,967	0	0	0	3	15,912	3.0	0.0003	4.8	78
	12	PVC	274	0	0							
	4	ACP	5	0	0							
	6	ACP	3,293	0	2							
	6	DIP	20	0	0							
6N	8	ACP	11	0	1	0	1	14,812	1.0	0.0001	1.5	109
	8	DIP	3,259	0	0							
	12	DIP	7,879	0	0							
	4	ACP	316	0	0							
	6	ACP	731	0	0							
7A1	6	DIP	42	0	0	0	3	7,392	3.0	0.0003	2.2	98
	8	ACP	47	0	1							
	8	DIP	8,416	0	0							
	12	DIP	3,914	0	0							
	6	ACP	574	0	0							
7A2	8	ACP	3,137	0	2	0	1	10,560	1.0	0.0001	1.1	113
	8	PVC	3,033	0	1							
	12	PVC	531	0	0							
	MAFB	UNK	850	0	0							
	6	ACP	191	0	0							
7B1	6	CIP	394	0	0	0	1	5,280	1.0	0.0001	0.5	124
	6	PVC	85	0	0							
	8	ACP	835	0	0							
	8	PVC	320	0	1							
	12	PVC	1,483	0	0							
7B2	MAFB	UNK	10,490	0	0	0	3	6,864	3.0	0.0003	2.1	101
	6	ACP	3,782	0	1							
	MAFB	UNK	657	0	0							
	6	ACP	836	0	0							
	8	ACP	2,039	0	0							
7B3	10	ACP	3,888	0	2	0	5	9,504	5.0	0.0005	4.8	79
	10	DIP	6	0	1							
	MAFB	UNK	471	0	0							
	6	ACP	2,257	0	2							
	8	ACP	1,325	0	0							
7B4	8	DIP	1,188	0	0	0	3	9,504	3	0.0003	2.9	93
	10	ACP	2,744	0	2							
	10	CIP	240	0	0							
	12	DIP	48	0	0							
	MAFB	UNK	841	0	1							
	6	ACP	702	0	1							
	6	DIP	16	0	0							
	6	PVC	507	0	0							
	8	ACP	898	0	0							
	8	PVC	478	0	0							
	10	ACP	1,730	0	0							
10	DIP	317	0	0								
10	UNK	202	0	0								
12	ACP	161	0	1								
12	DIP	38	0	0								
12	PVC	402	0	1								
MAFB	UNK	3,065	0	0								
7B5	MAFB	UNK	1,979	0	0	0	0	1,320	0	0.0000	0.0	132
7C1	6	ACP	2,133	0	0	0	2	10,032	2	0.0002	2.0	102
	6	ODS	217	0	1							
	8	ODS	172	0	1							
	10	ACP	661	0	0							
	10	PVC	1,510	0	0							
7C2	MAFB	UNK	439	0	0	0	0	6,336	0	0.0000	0.0	132
	4	ACP	36	0	0							
	6	ACP	931	0	0							
	10	ACP	1,807	0	0							
	10	CIP	1,299	0	0							
MAFB	UNK	128	0	0								

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
7C3	4	ACP	89	0	0	0	2	7,920	2	0.0002	1.6	107
	6	ACP	75	0	0							
	8	ACP	230	0	1							
	10	ACP	1603	0	0							
	10	CIP	806	0	0							
	10	DIP	6	0	1							
	10	PVC	1099	0	0							
MAFB	UNK	2925	0	0								
7C4	4	CIP	7	0	0	0	4	10,560	4	0.0004	4.2	82
	6	ACP	1,953	0	0							
	6	CIP	1,102	0	1							
	8	ACP	17	0	0							
	8	DIP	159	0	0							
	10	ACP	1,938	0	0							
	10	PVC	175	0	0							
	12	ACP	3,224	0	3							
	12	DIP	765	0	0							
MAFB	UNK	3,002	0	0								
7C5	4	CIP	427	0	0	0	5	10,560	5	0.0005	5.3	76
	6	ACP	1443	0	2							
	6	CIP	2040	0	2							
	6	DIP	254	0	0							
	6	PVC	691	0	0							
	8	ACP	472	0	0							
	8	DIP	107	0	1							
	10	ACP	5	0	0							
	10	CIP	112	0	0							
MAFB	UNK	683	0	0								
7D1	6	ACP	2757	0	1	0	23	8,448	23	0.0023	19.4	40
	6	CIP	1818	0	0							
	6	UNK	7	0	0							
	8	ACP	1348	0	3							
	8	CIP	390	0	0							
	10	ACP	3273	0	11							
	10	CIP	3370	0	1							
	12	ACP	438	0	0							
	12	DIP	593	0	1							
	14	ACP	440	0	3							
	14	DIP	4	0	1							
	16	ACP	1476	0	1							
	16	DIP	18	0	0							
	20	DIP	255	0	0							
MAFB	UNK	2822	0	1								
7D2	4	CIP	34	0	0	0	4	8,976	4	0.0004	3.6	85
	6	ACP	1456	0	2							
	6	CIP	321	0	0							
	8	CIP	878	0	0							
	10	ACP	791	0	1							
	10	CIP	3209	0	0							
	10	DIP	125	0	0							
MAFB	UNK	2002	0	1								
7D3	6	ACP	2086	0	2	0	6	9,504	6	0.0006	5.7	72
	6	CIP	1177	0	1							
	6	DIP	48	0	1							
	8	CIP	1177	0	1							
	8	DIP	198	0	0							
	10	ACP	373	0	0							
	10	CIP	3556	0	1							
MAFB	UNK	2891	0	0								
7E1	6	ACP	631	0	1	0	2	9,504	2	0.0002	1.9	103
	6	CIP	493	0	0							
	8	ACP	740	0	0							
	8	CIP	236	0	0							
	8	DIP	361	0	0							
	10	ACP	7143	0	1							
	10	CIP	1231	0	0							
	10	DIP	210	0	0							
MAFB	UNK	2518	0	0								
7E2	6	ACP	57	0	0	0	0	3,696	0	0.0000	0.0	132
	10	ACP	3940	0	0							
	MAFB	UNK	320	0	0							
7E3	6	ACP	725	0	0	0	1	8,976	1	0.0001	0.9	117
	6	CIP	932	0	0							
	8	ACP	1193	0	1							
	10	ACP	4075	0	0							
	12	PVC	783	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
7E4	2	GALV	124	0	0	0	0	8,976	0	0.0000	0.0	132
	6	ACP	174	0	0							
	6	CIP	558	0	0							
	6	CONC	792	0	0							
	8	ACP	1397	0	0							
	8	CIP	391	0	0							
	10	ACP	838	0	0							
	12	PVC	99	0	0							
7F1	MAFB	UNK	4894	0	0	0	0	9,504	0	0.0000	0.0	132
	8	ACP	749	0	0							
	8	CIP	103	0	0							
	8	DIP	12	0	0							
	8	PVC	376	0	0							
	10	ACP	2074	0	0							
	10	CIP	1124	0	0							
	12	DIP	1307	0	0							
7F2	MAFB	UNK	1836	0	0	0	3	10,560	3	0.0003	3.2	91
	4	CIP	77	0	0							
	6	CIP	868	0	0							
	8	ACP	1059	0	0							
	8	CIP	1193	0	2							
	10	ACP	362	0	0							
7F3	10	CIP	4519	0	1	0	0	10,560	0	0.0000	0.0	132
	MAFB	UNK	746	0	0							
	4	DIP	51	0	0							
	8	ACP	572	0	0							
	8	DIP	180	0	0							
	10	ACP	23	0	0							
	12	ACP	3101	0	0							
	12	CIP	386	0	0							
	12	DIP	186	0	0							
	12	MLS	791	0	0							
7F4	12	PVC	926	0	0	0	1	6,336	1	0.0001	0.6	121
	MAFB	UNK	3817	0	0							
	2	GALV	512	0	0							
	4	CIP	500	0	0							
	4	DIP	222	0	0							
	4	GALV	147	0	0							
	6	ACP	237	0	0							
	6	UNK	407	0	0							
	8	ACP	1368	0	1							
	8	CIP	451	0	0							
	8	DIP	240	0	0							
	10	ACP	1445	0	0							
	12	CIP	972	0	0							
	12	DIP	328	0	0							
12	MLS	148	0	0								
7G1	MAFB	UNK	1861	0	0	0	0	5,280	0	0.0000	0.0	132
	6	PVC	398	0	0							
7G2	MAFB	UNK	5431	0	0	0	0	5,808	0	0.0000	0.0	132
	8	ACP	3133	0	0							
	8	DIP	620	0	0							
7G3	MAFB	UNK	1513	0	0	0	0	7,920	0	0.0000	0.0	132
	8	ACP	1678	0	0							
	8	DIP	26	0	0							
	10	ACP	2175	0	0							
	12	ACP	1259	0	0							
	12	CIP	1465	0	0							
7G4	16	ACP	141	0	0	0	2	8,976	2	0.0002	1.8	104
	MAFB	UNK	2072	0	0							
	8	DIP	306	0	0							
	10	ACP	5,373	0	2							
	10	DIP	7	0	0							
	12	ACP	277	0	0							
	12	CCP	804	0	0							
7G5	12	CIP	50	0	0	0	0	6,864	0	0.0000	0.0	132
	12	DIP	334	0	0							
	MAFB	UNK	1,899	0	0							
	2	GALV	124	0	0							
	8	ACP	3,111	0	0							
9	10	ACP	531	0	0	0	6	10,560	6.0	0.0006	6.3	68
	MAFB	UNK	2,924	0	0							
	4"	ACP	254	0	1							
	6"	ACP	8,117	0	4							
	8"	ACP	3,399	0	1	0	6	10,560	6.0	0.0006	6.3	68
	8"	DIP	144	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
10	4"	MLS	276	0	0	0	0	10,560	0.0	0.0000	0.0	132
	6"	ACP	250	0	0							
	6"	MLS	5,854	0	0							
	8"	MLS	3,709	0	0							
	10"	MLS	3,822	0	0							
11	12"	ACP	12	0	0	0	0	2,640	0.0	0.0000	0.0	132
	6"	ACP	2,620	0	0							
	8"	MLS	63	0	0							
12A	10"	MLS	505	0	0	2	4	42,240	5.0	0.0005	21.1	36
	4"	ACP	1,734	0	0							
	6"	ACP	22,661	2	2							
	6"	DIP	7	0	0							
	6"	MLS	2,882	0	0							
	8"	ACP	7,970	0	1							
	8"	DIP	92	0	0							
	8"	MLS	1,749	0	0							
	10"	ACP	2,556	0	0							
	10"	MLS	2,663	0	0							
	12"	ACP	333	0	0							
	12"	MLS	417	0	0							
	12"	PVC	175	0	0							
	14"	ACP	1,327	0	1							
	14"	MLS	3,849	0	0							
12B	4"	ACP	135	0	0	1	4	41,712	4.5	0.0005	18.8	42
	6"	ACP	16,696	0	2							
	8"	ACP	8,790	0	2							
	8"	DIP	387	0	0							
	10"	ACP	6,666	1	0							
	10"	MLS	152	0	0							
	12"	ACP	1,834	0	0							
	12"	CIP	37	0	0							
	12"	DIP	1,343	0	0							
	14"	ACP	3,821	0	0							
13A	14"	CIP	165	0	0	1	1	38,016	1.5	0.0002	5.7	72
	6"	ACP	2,255	0	0							
	6"	DIP	216	0	0							
	6"	MLS	4,397	0	0							
	6"	PVC	17	0	0							
	8"	ACP	2,651	0	0							
	8"	DIP	684	0	0							
	8"	MLS	1,683	0	1							
	8"	PVC	2,026	0	0							
	10"	MLS	37	0	0							
	12"	ACP	293	0	0							
	12"	DIP	1,246	0	0							
	12"	MLS	9,858	1	0							
12"	PVC	8,483	0	0								
13B	14"	DIP	409	0	0	5	1	33,264	3.5	0.0004	11.6	55
	14"	MLS	3,901	0	0							
	6"	ACP	2,678	1	0							
	6"	MLS	1,797	0	0							
	6"	PVC	1,017	0	0							
	8"	ACP	12,238	0	0							
	8"	CIP	315	0	0							
	8"	DIP	281	0	0							
	8"	PVC	4,036	1	1							
	10"	MLS	1,014	0	0							
	12"	ACP	3,816	2	0							
	12"	DIP	905	0	0							
	12"	MLS	1,632	0	0							
	12"	PVC	2,660	1	0							
14"	ACP	2,482	0	0								
14	14"	CIP	201	0	0	0	0	16,199	0.0	0.0000	0.0	132
	4"	ACP	56	0	0							
	6"	ACP	42	0	0							
	8"	ACP	2,572	0	0							
	8"	DIP	56	0	0							
15	8"	PVC	9,713	0	0	0	0	6,371	0.0	0.0000	0.0	132
	12"	PVC	2,287	0	0							
	6"	CIP	410	0	0							
15	6"	PVC	124	0	0	0	0	6,371	0.0	0.0000	0.0	132
	8"	PVC	4,099	0	0							
	12"	PVC	1,160	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
16	4"	ACP	1,558	0	0	0	0	5,861	0.0	0.0000	0.0	132
	6"	ACP	3,832	0	0							
	6"	DIP	6	0	0							
	8"	ACP	88	0	0							
	8"	DIP	1,292	0	0							
	8"	PVC	48	0	0							
17A	12"	DIP	19	0	0	1	2	42,240	2.5	0.0003	10.6	58
	4"	ACP	280	0	0							
	6"	ACP	8,316	0	1							
	6"	MLS	2,926	0	0							
	8"	ACP	6,315	0	0							
	8"	DIP	2,645	0	0							
	8"	MLS	4,359	0	0							
	8"	ODS	14	0	0							
	8"	PVC	7,339	1	0							
	8"	UNK	18	0	0							
	10"	ACP	32	0	0							
	10"	DIP	295	0	0							
	10"	MLS	4,493	0	1							
	12"	ACP	1,414	0	0							
12"	PVC	3,487	0	0								
17B	14"	MLS	15	0	0	3	6	39,600	7.5	0.0008	29.7	26
	2"	PVC	317	0	1							
	4"	ACP	367	0	1							
	4"	DIP	198	0	0							
	4"	PVC	51	0	0							
	6"	ACP	516	0	0							
	6"	MLS	2,568	0	0							
	6"	PVC	144	0	0							
	8"	ACP	6,392	0	1							
	8"	CIP	651	0	0							
	8"	MLS	73	0	0							
	8"	PVC	4,169	1	0							
	8"	UNK	3	0	0							
	10"	ACP	603	0	0							
	10"	MLS	3,953	2	0							
	12"	ACP	3,548	0	0							
	12"	CIP	71	0	1							
12"	DIP	1,539	0	1								
18	12"	PVC	20,562	0	1	3	6	44,880	7.5	0.0008	33.7	21
	4"	ACP	317	0	0							
	4"	MLS	12	0	0							
	6"	ACP	8,602	2	1							
	6"	DIP	452	0	0							
	6"	MLS	4,696	0	0							
	6"	PVC	112	0	0							
	8"	ACP	7,292	0	0							
	8"	DIP	154	0	0							
	8"	MLS	947	0	0							
	8"	PVC	1,828	1	0							
	10"	ACP	4,230	0	1							
	10"	DIP	524	0	0							
	10"	MLS	5,833	0	2							
	12"	ACP	1,848	0	0							
	12"	DIP	1,271	0	1							
19	12"	MLS	2,963	0	1	1	11	39,072	11.5	0.0012	44.9	15
	4"	ACP	921	0	0							
	5"	UNK	2	0	0							
	6"	ACP	12,727	0	3							
	6"	DIP	21	0	1							
	6"	MLS	2,868	0	1							
	6"	PVC	33	0	0							
	8"	ACP	7,797	0	0							
	8"	DIP	1,606	0	0							
	8"	MLS	1,538	0	0							
	8"	PVC	4,336	1	0							
	10"	ACP	930	0	0							
	10"	MLS	6,934	0	6							
	12"	DIP	1,540	0	0							
12"	PVC	6,880	0	0								
14"	MLS	21	0	0								

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
20A	2"	PVC	185	0	0	3	6	31,680	7.5	0.0008	23.8	30
	4"	ACP	7,975	1	2							
	4"	DIP	16	0	0							
	6"	ACP	15,214	1	4							
	6"	DIP	297	0	0							
	6"	PVC	200	0	0							
	8"	ACP	7,190	1	0							
	8"	DIP	393	0	0							
	8"	PVC	88	0	0							
	10"	ACP	1,310	0	0							
	12"	DIP	322	0	0							
12"	PVC	449	0	0								
20B	2"	PVC	1,849	0	1	3	6	42,240	7.5	0.0008	31.7	23
	2.5"	PVC	64	0	0							
	2"	COP	63	0	0							
	2"	GALV	186	0	0							
	4"	ACP	6,007	1	1							
	4"	DIP	131	0	0							
	4"	PVC	31	0	0							
	6"	ACP	14,282	1	3							
	8"	ACP	9,729	1	1							
	8"	DIP	2,526	0	0							
	8"	MLS	1,883	0	0							
	8"	PVC	1,655	0	0							
	10"	ACP	3,620	0	0							
	12"	ACP	759	0	0							
	12"	CIP	172	0	0							
	12"	DIP	1,723	0	0							
12"	MLS	1,212	0	0								
12"	PVC	1,530	0	0								
14"	MLS	1,945	0	0								
21	2"	COP	59	0	1	0	2	8,448	2.0	0.0002	1.7	105
	2"	PVC	235	0	0							
	4"	ACP	1,349	0	0							
	6"	ACP	2,879	0	1							
	8"	ACP	963	0	0							
	8"	DIP	1,855	0	0							
12"	DIP	62	0	0								
22	2"	PVC	80	0	0	0	0	4,752	0.0	0.0000	0.0	132
	4"	ACP	740	0	0							
	6"	ACP	2,231	0	0							
	8"	ACP	933	0	0							
	12"	PVC	38	0	0							
23	2"	ACP	360	0	0	2	9	58,080	10.0	0.0010	58.1	12
	2"	COP	86	0	0							
	2"	GALV	401	0	0							
	2"	PVC	527	0	0							
	4"	ACP	10,103	0	4							
	6"	ACP	42,772	0	3							
	8"	ACP	11,209	2	2							
	8"	DIP	1,941	0	0							
	8"	PVC	428	0	0							
	10"	ACP	2	0	0							
	12"	DIP	124	0	0							
12"	PVC	278	0	0								
24A	6"	ACP	3,844	0	0	0	0	42,240	0.0	0.0000	0.0	132
	6"	DIP	228	0	0							
	6"	MLS	6,903	0	0							
	8"	ACP	9,702	0	0							
	8"	CIP	511	0	0							
	8"	DIP	1,874	0	0							
	8"	PVC	3,673	0	0							
	10"	ACP	11,644	0	0							
	10"	CIP	78	0	0							
	10"	DIP	64	0	0							
	10"	MLS	3,051	0	0							
	12"	DIP	466	0	0							
	12"	PVC	5,629	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
24B	4"	ACP	1,226	0	0	1	4	44,880	4.5	0.0005	20.2	39
	4"	MLS	179	0	0							
	6"	ACP	15,534	1	2							
	6"	MLS	5,551	0	0							
	8"	ACP	5,485	0	0							
	8"	DIP	73	0	0							
	8"	PVC	1,854	0	0							
	10"	ACP	2,043	0	0							
	10"	MLS	6,173	0	2							
	12"	ACP	4,371	0	0							
	12"	CIP	60	0	0							
	12"	DIP	229	0	0							
12"	PVC	10,094	0	0								
25	2"	GALV	89	0	0	0	1	7,392	1.0	0.0001	0.7	119
	4"	ACP	1,449	0	1							
	6"	ACP	4,264	0	0							
	8"	ACP	152	0	0							
	8"	PVC	26	0	0							
	10"	MLS	203	0	0							
12"	PVC	1,157	0	0								
26A	4"	ACP	788	0	0	0	1	21,120	1.0	0.0001	2.1	99
	6"	ACP	3,576	0	0							
	6"	DIP	176	0	0							
	6"	MLS	9,355	0	0							
	8"	ACP	858	0	0							
	8"	DIP	3,671	0	0							
	8"	MLS	450	0	0							
	8"	PVC	860	0	0							
	10"	ACP	722	0	0							
	10"	DIP	10	0	1							
	10"	MLS	3,066	0	0							
	12"	ACP	383	0	0							
	12"	DIP	1,034	0	0							
	12"	MLS	1,512	0	0							
12"	PVC	3,138	0	0								
26B	2"	GALV	100	0	0	1	5	29,040	5.5	0.0006	16.0	49
	4"	ACP	1,536	0	0							
	4"	MLS	6	0	0							
	6"	ACP	11,538	0	2							
	6"	DIP	68	0	0							
	6"	MLS	7,878	0	1							
	6"	PVC	157	0	0							
	8"	ACP	3,405	1	0							
	8"	DIP	758	0	0							
	8"	MLS	4,076	0	1							
	8"	PVC	1,499	0	0							
	10"	ACP	395	0	0							
	12"	ACP	1,278	0	0							
	12"	DIP	1,249	0	0							
	12"	MLS	3,376	0	1							
	12"	PVC	4,182	0	0							
27	4"	ACP	321	0	0	1	7	30,624	7.5	0.0008	23.0	33
	6"	ACP	5,064	1	1							
	6"	DIP	73	0	0							
	6"	MLS	4,711	0	3							
	8"	ACP	1,816	0	0							
	8"	DIP	1,686	0	0							
	8"	MLS	2,942	0	1							
	8"	PVC	1,890	0	0							
	10"	ACP	1,179	0	0							
	10"	MLS	1,871	0	0							
	12"	ACP	323	0	0							
	12"	DIP	3,081	0	0							
	12"	MLS	5,393	0	2							
	12"	PVC	1,718	0	0							
28	4"	ACP	146	0	0	1	7	43,824	7.5	0.0008	32.9	22
	4"	PVC	21	0	0							
	6"	ACP	19,032	0	3							
	6"	MLS	1,051	0	0							
	8"	ACP	8,324	0	1							
	8"	DIP	140	0	1							
	8"	MLS	9,922	0	2							
	8"	PVC	3,018	1	0							
	10"	ACP	180	0	0							
	10"	MLS	2,302	0	0							
	12"	ACP	308	0	0							
	12"	DIP	115	0	0							
	12"	MLS	1,436	0	0							
	12"	PVC	6,210	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
29	2"	ACP	71	0	0	4	2	41,712	4.0	0.0004	16.7	47
	4"	ACP	1,120	0	0							
	6"	ACP	11,639	1	0							
	6"	DIP	616	0	0							
	6"	MLS	1,208	0	1							
	8"	ACP	17,126	0	1							
	8"	DIP	1,852	0	0							
	8"	MLS	1,228	0	0							
	10"	CIP	105	0	0							
	10"	MLS	8,417	1	0							
	12"	ACP	816	0	0							
	12"	DIP	3,306	0	0							
12"	PVC	2,508	2	0								
30	6"	ACP	3,022	0	0	0	0	3,168	0.0	0.0000	0.0	132
	8"	PVC	196	0	0							
31A	2"	COP	159	0	0	1	2	23,760	2.5	0.0003	5.9	71
	4"	ACP	2,438	0	0							
	6"	ACP	16,404	1	2							
	8"	ACP	4,015	0	0							
	8"	DIP	2,089	0	0							
	8"	PVC	526	0	0							
	10"	ACP	114	0	0							
12"	PVC	981	0	0								
31B	2"	ABS	250	0	0	0	0	1,056	0.0	0.0000	0.0	132
	4"	ACP	96	0	0							
	6"	ACP	297	0	0							
	8"	ACP	493	0	0							
32	2"	GALV	69	0	0	0	4	8,976	4.0	0.0004	3.6	85
	2"	PVC	308	0	0							
	4"	ACP	1,242	0	3							
	6"	ACP	6,686	0	1							
	6"	PVC	7	0	0							
	8"	ACP	1,052	0	0							
	10"	ACP	994	0	0							
12"	ACP	170	0	0								
33	2"	GALV	75	0	0	0	5	15,840	5.0	0.0005	7.9	60
	2"	PVC	155	0	1							
	4"	ACP	813	0	0							
	6"	ACP	9,359	0	3							
	8"	ACP	4,770	0	1							
12"	DIP	2,579	0	0								
34	4"	ACP	1,145	0	1	0	2	5,280	2.0	0.0002	1.1	113
	6"	ACP	2,558	0	1							
	8"	ACP	811	0	0							
	10"	MLS	1,260	0	0							
	12"	ACP	31	0	0							
35	4"	ACP	211	0	0	0	8	36,960	8.0	0.0008	29.6	27
	6"	ACP	15,092	0	3							
	6"	MLS	6,545	0	0							
	8"	ACP	937	0	0							
	8"	DIP	422	0	0							
	8"	MLS	6,163	0	5							
	8"	PVC	260	0	0							
	10"	ACP	4	0	0							
	10"	MLS	2,879	0	0							
12"	PVC	17	0	0								
36	4"	ACP	232	0	0	1	5	38,016	5.5	0.0006	20.9	38
	4"	DIP	62	0	0							
	6"	ACP	13,338	0	1							
	6"	MLS	10,448	0	1							
	8"	ACP	3,038	0	1							
	8"	DIP	2,513	0	0							
	8"	MLS	6,455	0	2							
	8"	PVC	3,224	1	0							
	10"	ACP	699	0	0							
	12"	ACP	1,423	0	0							
	12"	DIP	255	0	0							
12"	PVC	4,165	0	0								
37	4"	ACP	28	0	0	0	0	3,168	0.0	0.0000	0.0	132
	6"	ACP	1,989	0	0							
	6"	MLS	866	0	0							
	8"	MLS	455	0	0							
	12"	DIP	15	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
38A	2"	GALV	75	0	0	4	9	32,208	11.0	0.0011	35.4	19
	3"	UNK	61	0	0							
	4"	ACP	130	0	0							
	6"	ACP	18,379	4	5							
	6"	CIP	301	0	0							
	6"	DIP	32	0	0							
	6"	UNK	61	0	0							
	6"	MLS	1,246	0	0							
	6"	PVC	50	0	0							
	8"	ACP	7,857	0	4							
	8"	CIP	90	0	0							
	8"	DIP	151	0	0							
	8"	UNK	26	0	0							
	8"	MLS	1,009	0	0							
	8"	PVC	1,148	0	0							
	38B	2"	GALV	139	0							
4"		ACP	721	0	0							
6"		ACP	17,111	1	2							
6"		CIP	4	0	0							
6"		DIP	823	0	0							
6"		MLS	5,474	0	2							
8"		ACP	5,071	0	0							
8"		DIP	769	0	0							
8"		MLS	1,870	0	1							
8"		PVC	848	0	0							
10"		ACP	1,702	0	0							
10"		MLS	3,129	0	0							
39	2"	GALV	399	0	1	0	2	11,616	2.0	0.0002	2.3	96
	4"	ACP	1,458	0	0							
	6"	ACP	5,867	0	1							
	6"	CIP	688	0	0							
	6"	PVC	346	0	0							
	8"	ACP	2,846	0	0							
	8"	DIP	103	0	0							
	8"	PVC	3	0	0							
	10"	UNK	30	0	0							
	12"	MLS	52	0	0							
40A	4"	ACP	600	0	0	1	4	27,456	4.5	0.0005	12.4	54
	6"	ACP	5,778	0	0							
	6"	DIP	126	0	0							
	6"	PVC	38	0	0							
	8"	ACP	6,789	0	0							
	8"	DIP	3,261	0	0							
	8"	MLS	1,516	1	0							
	8"	PVC	581	0	0							
	10"	MLS	1,177	0	3							
40B	4"	ACP	2,306	0	1	1	3	35,904	3.5	0.0004	12.6	53
	6"	ACP	9,014	1	1							
	6"	DIP	167	0	0							
	6"	MLS	4,110	0	0							
	8"	ACP	1,849	0	0							
	8"	DIP	2,350	0	0							
	8"	MLS	3,639	0	1							
	8"	PVC	42	0	0							
	10"	ACP	568	0	0							
	12"	ACP	2,080	0	0							
	12"	DIP	338	0	0							
41	2"	ACP	334	0	1	1	2	13,728	2.5	0.0003	3.4	88
	4"	ACP	1,454	0	0							
	6"	ACP	11,923	1	1							
	6"	PVC	6	0	0							
	8"	ACP	3,481	0	0							
	8"	DIP	20	0	0							
	12"	PVC	32	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
42A	4"	ACP	548	0	2	0	3	3,696	3.0	0.0003	1.1	112
	4"	ODS	16	0	0							
	6"	ACP	1,829	0	1							
	8"	DIP	104	0	0							
	10"	UNK	22	0	0							
	12"	DIP	1,303	0	0							
42B	1.5"	GALV	292	0	2	1	20	19,008	20.5	0.0021	39.0	16
	2"	COP	245	0	0							
	2"	GALV	1,400	0	0							
	2"	PET	130	0	0							
	4"	ACP	1,396	0	2							
	4"	ODS	436	0	1							
	4"	PVC	379	0	0							
	6"	ACP	8,398	1	13							
	6"	DIP	231	0	0							
	6"	ODS	181	0	2							
	6"	PVC	942	0	0							
	8"	ACP	86	0	0							
	8"	DIP	679	0	0							
	8"	PVC	179	0	0							
12"	DIP	965	0	0								
42C	2"	GALV	255	0	0	0	2	11,616	2.0	0.0002	2.3	96
	4"	ACP	1,298	0	0							
	6"	ACP	4,505	0	2							
	6"	DIP	56	0	0							
	6"	UNK	37	0	0							
	8"	ACP	1,780	0	0							
	8"	DIP	1,199	0	0							
	8"	PVC	1,256	0	0							
12"	DIP	57	0	0								
42D	2"	GALV	75	0	0	0	3	14,256	3.0	0.0003	4.3	81
	4"	ACP	2,428	0	0							
	4"	UNK	45	0	0							
	6"	ACP	5,588	0	2							
	6"	UNK	23	0	0							
	8"	ACP	3,419	0	0							
	8"	DIP	8	0	1							
8"	PVC	14	0	0								
42E	2"	GALV	365	0	2	1	12	16,896	12.5	0.0013	21.1	36
	4"	ACP	6,182	0	4							
	6"	ACP	8,814	0	4							
	8"	ACP	5,293	1	2							
42F	4"	ACP	7	0	0	0	4	10,560	4.0	0.0004	4.2	82
	6"	ACP	169	0	0							
	8"	ACP	3,771	0	4							
	8"	DIP	316	0	0							
	8"	UNK	60	0	0							
	8"	PVC	184	0	0							
	10"	ACP	1,694	0	0							
	10"	DIP	71	0	0							
	10"	UNK	118	0	0							
	12"	ACP	1,527	0	0							
12"	DIP	2,170	0	0								
42G	4"	ACP	1	0	0	0	3	3,002	3.0	0.0003	0.9	116
	6"	ACP	1,478	0	3							
	8"	DIP	1,250	0	0							
43A	2"	GALV	185	0	0	0	5	6,864	5.0	0.0005	3.4	88
	4"	ACP	2,595	0	2							
	4"	UNK	12	0	0							
	6"	ACP	4,572	0	2							
	6"	DIP	22	0	0							
	8"	ACP	2,666	0	1							
	8"	DIP	30	0	0							
	8"	PVC	1,398	0	0							
	10"	PVC	15	0	0							
	12"	DIP	8	0	0							
12"	PVC	544	0	0								
43B	8"	DIP	105	0	0	0	0	116	0.0	0.0000	0.0	132
43C	6"	ACP	424	0	0	0	1	1,656	1.0	0.0001	0.2	130
	6"	DIP	81	0	0							
	8"	ACP	230	0	1							
	8"	DIP	762	0	0							
	12"	PVC	8	0	0							
43D	4"	ACP	238	0	0	0	0	1,584	0.0	0.0000	0.0	132
	8"	DIP	348	0	0							
	8"	PVC	839	0	0							
	12"	DIP	15	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
44	2"	GALV	55	0	0	0	2	17,424	2.0	0.0002	3.5	87
	4"	ACP	479	0	1							
	6"	ACP	3,961	0	0							
	6"	DIP	19	0	0							
	6"	PVC	14	0	0							
	8"	ACP	5,265	0	1							
	8"	DIP	2,603	0	0							
	8"	ODS	96	0	0							
	8"	PVC	2,842	0	0							
	10"	ACP	313	0	0							
	10"	PVC	265	0	0							
	12"	ACP	1,073	0	0							
12"	DIP	2,903	0	0								
12"	PVC	6,466	0	0								
45A	4"	ODS	1	0	0	0	1	46,800	1.0	0.0001	4.7	80
	6"	ACP	216	0	0							
	6"	DIP	400	0	0							
	6"	ODS	336	0	0							
	6"	PVC	336	0	0							
	8"	ACP	1,314	0	1							
	8"	DIP	13,844	0	0							
	8"	PVC	4,387	0	0							
	8"	UNK	18	0	0							
	10"	ACP	8	0	0							
	12"	ACP	9	0	0							
	12"	DIP	17,055	0	0							
12"	PVC	4,625	0	0								
45B	2"	GALV	226	0	3	0	8	9,452	8.0	0.0008	7.6	63
	4"	ACP	1,807	0	1							
	4"	DIP	34	0	0							
	4"	UNK	23	0	0							
	6"	ACP	2,913	0	3							
	6"	PVC	104	0	0							
	8"	ACP	1,279	0	0							
	8"	DIP	526	0	0							
	8"	ODS	42	0	1							
	8"	PVC	933	0	0							
	12"	DIP	684	0	0							
	12"	PVC	22	0	0							
46	4"	ODS	645	0	0	0	0	13,632	0.0	0.0000	0.0	132
	6"	ACP	9	0	0							
	6"	ODS	1,108	0	0							
	6"	PVC	67	0	0							
	8"	DIP	67	0	0							
	8"	ODS	626	0	0							
	8"	PVC	9,340	0	0							
	12"	DIP	37	0	0							
12"	PVC	494	0	0								
47	6"	PVC	1,488	0	1	0	1	2,112	1.0	0.0001	0.2	127
	8"	DIP	25	0	0							
48	8"	PVC	123	0	0	1	49	17,424	49.5	0.0050	86.2	5
	2"	GALV	308	0	0							
	4"	ACP	1,591	0	6							
	4"	ODS	5,607	1	19							
	4"	PVC	45	0	0							
	6"	ACP	2,806	0	3							
	6"	ODS	9,035	0	18							
	8"	ACP	1,313	0	1							
	8"	ODS	329	0	2							
	8"	PVC	759	0	0							
12"	DIP	378	0	0								
12"	PVC	22	0	0								
49	6"	ODS	20	0	0	0	0	3,306	0.0	0.0000	0.0	132
	8"	DIP	12	0	0							
	8"	ODS	132	0	0							
	8"	PVC	2,472	0	0							
	12"	PVC	369	0	0							
51	6"	ACP	725	0	0	0	0	36,619	0.0	0.0000	0.0	132
	6"	DIP	682	0	0							
	6"	ODS	20	0	0							
	6"	PVC	27	0	0							
	8"	ACP	58	0	0							
	8"	DIP	16,995	0	0							
	8"	PVC	2,562	0	0							
	12"	DIP	12,189	0	0							
12"	PVC	33	0	0								

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
52A	2"	GALV	1	0	0	0	9	18,899	9.0	0.0009	17.0	46
	4"	ACP	573	0	0							
	6"	ACP	2,545	0	4							
	6"	DIP	98	0	0							
	8"	ACP	3,269	0	5							
	8"	DIP	2,701	0	0							
	10"	ACP	47	0	0							
	10"	DIP	109	0	0							
52B	12"	DIP	7,837	0	0	0	0	12,046	0.0	0.0000	0.0	132
	6"	DIP	207	0	0							
	8"	DIP	4,372	0	0							
53	12"	DIP	6,372	0	0	1	13	22,704	13.5	0.0014	30.7	25
	2"	GALV	252	0	9							
	4"	ACP	2,274	0	0							
	4"	UNK	15	0	0							
	6"	ACP	22,640	1	4							
	6"	ODS	14	0	0							
	8"	ACP	1,837	0	0							
	8"	DIP	256	0	0							
	8"	PVC	2,539	0	0							
	10"	ACP	113	0	0							
54	12"	DIP	1,482	0	0	0	2	10,560	2.0	0.0002	2.1	99
	2"	ACP	331	0	0							
	4"	ACP	2,335	0	0							
	6"	ACP	6,103	0	2							
	8"	PVC	992	0	0							
55	12"	DIP	558	0	0	2	3	31,680	4.0	0.0004	12.7	52
	2"	GALV	50	0	0							
	4"	ACP	1,539	1	0							
	4"	PVC	78	0	0							
	6"	ACP	21,943	1	3							
	6"	DIP	184	0	0							
	6"	UNK	23	0	0							
	6"	MLS	1,507	0	0							
	8"	ACP	4,770	0	0							
	8"	DIP	232	0	0							
	8"	UNK	5	0	0							
	8"	MLS	1,488	0	0							
	8"	PVC	1,712	0	0							
	10"	ACP	167	0	0							
	10"	UNK	12	0	0							
	12"	ACP	1,313	0	0							
12"	DIP	1,485	0	0								
12"	PVC	426	0	0								
56A	1.25"	GALV	198	0	4	0	57	26,928	57.0	0.0057	153.5	3
	2"	COP	103	0	4							
	2"	GALV	1,878	0	17							
	4"	ACP	3,469	0	0							
	4"	UNK	46	0	0							
	4"	ODS	1,575	0	0							
	6"	ACP	9,673	0	2							
	6"	ODS	12,032	0	29							
	8"	ACP	958	0	0							
	8"	DIP	29	0	0							
	8"	ODS	2,163	0	1							
	10"	PVC	45	0	0							
	12"	DIP	99	0	0							
	12"	PVC	5	0	0							
56B	2"	GALV	132	0	2	0	10	7,392	10.0	0.0010	7.4	65
	4"	ACP	1,492	0	0							
	6"	ACP	2,259	0	7							
	6"	ODS	1,020	0	1							
	6"	PVC	599	0	0							
	8"	PVC	501	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
57	2"	COP	142	0	6	2	26	29,040	27.0	0.0027	78.4	7
	2"	GALV	520	0	2							
	3"	UNK	36	0	0							
	4"	ACP	4,098	0	1							
	4"	UNK	46	0	0							
	6"	ACP	19,782	1	16							
	6"	DIP	129	0	0							
	6"	UNK	23	0	0							
	6"	MLS	1,348	1	0							
	6"	ODS	206	0	0							
	6"	PVC	434	0	0							
	8"	ACP	5,989	0	1							
	8"	DIP	1,788	0	0							
	8"	MLS	1,944	0	0							
	8"	PVC	4,138	0	0							
	8"	UNK	5	0	0							
10"	UNK	21	0	0								
12"	DIP	529	0	0								
12"	PVC	3,068	0	0								
58A	2"	GALV	109	0	0	0	5	15,476	5.0	0.0005	7.7	61
	4"	ACP	119	0	2							
	6"	ACP	336	0	0							
	6"	PVC	328	0	0							
	8"	DIP	9,832	0	0							
	12"	DIP	2,831	0	3							
12"	PVC	515	0	0								
58B	4"	ACP	151	0	0	0	0	4,399	0.0	0.0000	0.0	132
	6"	ACP	146	0	0							
	8"	ACP	114	0	0							
	8"	DIP	2,373	0	0							
12"	DIP	1,215	0	0								
58C	6"	ACP	21	0	0	0	0	1,015	0.0	0.0000	0.0	132
	12"	DIP	901	0	0							
59	8"	ACP	98	0	0	0	0	8,085	0.0	0.0000	0.0	132
	8"	DIP	4,341	0	0							
	8"	PVC	998	0	0							
	12"	DIP	1,912	0	0							
60	8"	DIP	228	0	0	0	0	467	0.0	0.0000	0.0	132
	12"	DIP	196	0	0							
60A	8"	ACP	139	0	0	0	1	12,123	1.0	0.0001	1.2	111
	8"	DIP	8,999	0	1							
	12"	DIP	1,883	0	0							
60B	8"	DIP	2,477	0	0	0	0	6,673	0.0	0.0000	0.0	132
	8"	ODS	33	0	0							
	8"	PVC	2	0	0							
	10"	UNK	17	0	0							
	10"	PVC	1,429	0	0							
12"	DIP	2,109	0	0								
61	4"	DIP	2	0	0	0	0	6,258	0.0	0.0000	0.0	132
	6"	DIP	10	0	0							
	8"	ACP	31	0	0							
	8"	DIP	2,804	0	0							
	8"	PVC	131	0	0							
	12"	DIP	2,710	0	0							
62	8"	DIP	4,890	0	0	0	0	5,632	0.0	0.0000	0.0	132
	12"	DIP	229	0	0							
63	6"	ACP	18	0	0	0	0	36,076	0.0	0.0000	0.0	132
	6"	UNK	46	0	0							
	6"	ODS	65	0	0							
	6"	PVC	3,310	0	0							
	8"	ACP	335	0	0							
	8"	DIP	315	0	0							
	8"	UNK	3	0	0							
	8"	PVC	24,464	0	0							
	10"	UNK	23	0	0							
	10"	PVC	28	0	0							
	12"	DIP	242	0	0							
	12"	PVC	3,947	0	0							
64	8"	DIP	2,710	0	0	0	0	3,686	0.0	0.0000	0.0	132
	12"	DIP	641	0	0							
65	6"	ACP	151	0	0	0	0	14,605	0.0	0.0000	0.0	132
	6"	DIP	24	0	0							
	6"	ODS	118	0	0							
	8"	ACP	823	0	0							
	8"	DIP	7,069	0	0							
	8"	ODS	407	0	0							
	8"	PVC	34	0	0							
12"	DIP	4,651	0	0								

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
66A	6"	ACP	285	0	2	0	2	7,013	2.0	0.0002	1.4	110
	6"	DIP	52	0	0							
	6"	ODS	21	0	0							
	6"	PVC	45	0	0							
	8"	DIP	2,397	0	0							
	8"	ODS	84	0	0							
	8"	PVC	1,918	0	0							
	8"	UNK	62	0	0							
	10"	PVC	117	0	0							
12"	DIP	1,393	0	0								
66B	4"	ACP	188	0	1	0	3	1,584	3.0	0.0003	0.5	125
	5"	UNK	136	0	0							
	6"	ACP	1,895	0	1							
	6"	DIP	19	0	0							
	6"	PVC	1,160	0	0							
	8"	ACP	1,737	0	1							
	8"	DIP	11	0	0							
	8"	UNK	52	0	0							
	8"	ODS	89	0	0							
66C	6"	ACP	1,870	0	0	0	0	1,056	0.0	0.0000	0.0	132
	6"	DIP	120	0	0							
	6"	PVC	2	0	0							
	8"	DIP	129	0	0							
	8"	PVC	458	0	0							
66D	12"	DIP	213	0	0	0	2	1,056	2.0	0.0002	0.2	127
	6"	ACP	413	0	1							
	6"	ODS	436	0	1							
	8"	ACP	725	0	0							
66E	10"	PVC	24	0	0	1	6	3,696	6.5	0.0007	2.4	95
	12"	DIP	507	0	0							
	3"	UNK	4	0	0							
	6"	ACP	4,538	1	6							
	6"	DIP	43	0	0							
	6"	UNK	20	0	0							
	6"	PVC	20	0	0							
	8"	ACP	3	0	0							
8"	DIP	38	0	0								
12"	DIP	2,697	0	0								
66F	12"	DIP	597	0	0	0	0	898	0.0	0.0000	0.0	132
67	3"	UNK	103	0	0	0	0	1,989	0.0	0.0000	0.0	132
	4"	UNK	31	0	0							
	8"	ACP	445	0	0							
	8"	DIP	728	0	0							
	12"	DIP	501	0	0							
68	6"	DIP	10	0	0	0	0	989	0.0	0.0000	0.0	132
	8"	DIP	11	0	0							
	8"	ODS	3	0	0							
	8"	PVC	875	0	0							
69	6"	ACP	12	0	0	0	0	5,455	0.0	0.0000	0.0	132
	8"	DIP	4,126	0	0							
	12"	DIP	821	0	0							
70	4"	ODS	53	0	0	0	2	34,070	2.0	0.0002	6.8	66
	6"	ACP	1,399	0	0							
	6"	DIP	16	0	0							
	8"	ACP	161	0	0							
	8"	DIP	17,761	0	0							
	8"	ODS	199	0	2							
	12"	DIP	11,383	0	0							
71	4"	ACP	28	0	0	0	1	28,416	1.0	0.0001	2.8	94
	6"	ACP	126	0	0							
	6"	DIP	9	0	0							
	6"	ODS	43	0	0							
	6"	PVC	37	0	0							
	8"	ACP	1,016	0	0							
	8"	DIP	13,221	0	0							
	8"	PVC	3,395	0	1							
	10"	ACP	178	0	0							
	10"	DIP	27	0	0							
	10"	PVC	33	0	0							
	12"	ACP	231	0	0							
	12"	DIP	7,484	0	0							
	12"	PVC	5	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
72	4"	ACP	3,514	0	1	0	4	9,504	4.0	0.0004	3.8	84
	6"	ACP	3,902	0	3							
	8"	ACP	1,846	0	0							
	8"	DIP	3	0	0							
	8"	PVC	118	0	0							
	10"	UNK	7	0	0							
	12"	ACP	4	0	0							
74	4"	ACP	3,498	0	1	1	3	8,448	3.5	0.0004	3.0	92
	4"	UNK	20	0	0							
	6"	ACP	6,263	0	2							
	6"	UNK	3	0	0							
	6"	PVC	10	0	0							
	8"	ACP	547	1	0							
	8"	DIP	3	0	0							
	8"	PVC	1,306	0	0							
	12"	MLS	5	0	0							
12"	PVC	139	0	0								
76A	4"	ACP	8	0	0	0	0	10,331	0.0	0.0000	0.0	132
	6"	ACP	514	0	0							
	6"	DIP	7	0	0							
	8"	ACP	1,957	0	0							
	8"	DIP	4,121	0	0							
	8"	PVC	534	0	0							
76B	6"	ACP	5	0	0	0	0	5,946	0.0	0.0000	0.0	132
	8"	DIP	2,811	0	0							
	12"	DIP	2,590	0	0							
76C	6"	ACP	278	0	0	0	2	2,957	2.0	0.0002	0.6	123
	6"	UNK	22	0	0							
	8"	ACP	1,655	0	2							
	8"	DIP	332	0	0							
	8"	PVC	449	0	0							
76D	10"	PVC	347	0	0	0	27	9,504	27.0	0.0027	25.7	29
	2"	GALV	235	0	6							
	4"	ACP	841	0	0							
	4"	ODS	1,037	0	8							
	6"	ACP	779	0	0							
	6"	ODS	3,587	0	5							
	6"	PVC	83	0	5							
	8"	ACP	660	0	0							
	8"	ODS	910	0	3							
	8"	PVC	1,454	0	0							
10"	PVC	24	0	0								
76F	12"	DIP	97	0	0	0	2	4,224	2.0	0.0002	0.8	118
	6"	ACP	1,864	0	0							
	6"	DIP	4	0	0							
	6"	ODS	808	0	2							
	8"	ACP	1,178	0	0							
	8"	DIP	33	0	0							
76G	8"	PVC	32	0	0	0	0	2,304	0.0	0.0000	0.0	132
	12"	DIP	72	0	0							
	6"	ACP	211	0	0							
	6"	DIP	30	0	0							
	8"	ACP	0	0	0							
76H	8"	DIP	11	0	0	0	4	2,587	4.0	0.0004	1.0	115
	12"	DIP	1,843	0	0							
	6"	ACP	2,288	0	4							
	6"	UNK	92	0	0							
	6"	ODS	54	0	0							
76I	8"	ACP	534	0	0	1	4	3,379	4.5	0.0005	1.5	108
	12"	DIP	659	0	0							
	4"	ACP	4	0	0							
	4"	PVC	591	0	0							
	6"	ACP	1,005	1	1							
	6"	ODS	436	0	0							
	8"	DIP	128	0	0							
	8"	UNK	6	0	0							
	8"	ODS	549	0	3							
	8"	PVC	586	0	0							
	10"	UNK	4	0	0							
10"	ODS	290	0	0								
10"	PVC	64	0	0								
76J	12"	DIP	226	0	0	0	0	1,584	0.0	0.0000	0.0	132
	6"	UNK	1	0	0							
	8"	ACP	453	0	0							
	8"	DIP	43	0	0							
	12"	DIP	640	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
76K	4"	ACP	14	0	0	0	0	1,347	0.0	0.0000	0.0	132
	6"	ACP	346	0	0							
	6"	UNK	1	0	0							
	6"	PVC	2	0	0							
	8"	ACP	42	0	0							
	8"	PVC	49	0	0							
77	12"	DIP	772	0	0	0	0	2,323	0.0	0.0000	0.0	132
	4"	ACP	933	0	0							
	6"	ACP	633	0	0							
	8"	ACP	492	0	0							
78	10"	PVC	3	0	0	0	12	14,256	12.0	0.0012	17.1	45
	2"	GALV	468	0	3							
	3"	UNK	99	0	0							
	4"	ACP	549	0	0							
	4"	ODS	419	0	0							
	6"	ACP	1,099	0	0							
	6"	DIP	294	0	5							
	6"	UNK	23	0	0							
	6"	ODS	7,191	0	0							
	8"	ACP	431	0	0							
	8"	DIP	311	0	0							
	8"	UNK	10	0	0							
	8"	ODS	3,141	0	4							
	8"	PVC	1,036	0	0							
10"	ODS	227	0	0								
12"	DIP	1,423	0	0								
79	12"	DIP	1,423	0	0	0	0	8,250	0.0	0.0000	0.0	132
	6"	ACP	98	0	0							
	6"	ODS	229	0	0							
	8"	DIP	4,678	0	0							
	8"	ODS	551	0	0							
	8"	PVC	1,898	0	0							
80	10"	UNK	42	0	0	1	62	28,512	62.5	0.0063	178.2	2
	10"	PVC	5	0	0							
	2"	GALV	414	0	2							
	4"	ACP	839	0	0							
	4"	ODS	4,932	1	4							
	6"	ACP	2,380	0	0							
	6"	DIP	108	0	1							
	6"	ODS	8,686	0	29							
	6"	PVC	267	0	4							
	8"	ACP	2,882	0	0							
	8"	DIP	1,974	0	0							
	8"	ODS	4,111	0	15							
	8"	PVC	1,832	0	6							
	10"	UNK	56	0	0							
12"	DIP	1,538	0	1								
81	12"	DIP	1,538	0	1	0	0	10,032	0.0	0.0000	0.0	132
	2"	GALV	4	0	0							
	4"	ODS	740	0	0							
	6"	ACP	4	0	0							
	6"	DIP	28	0	0							
	6"	ODS	1,871	0	0							
	8"	DIP	8,271	0	0							
	8"	ODS	11	0	0							
10"	ACP	1	0	0								
82	12"	DIP	2,900	0	0	0	5	13,200	5.0	0.0005	6.6	67
	3"	UNK	29	0	0							
	4"	ACP	67	0	0							
	4"	UNK	6	0	0							
	6"	ACP	2,672	0	3							
	8"	ACP	8,393	0	2							
	8"	DIP	1,090	0	0							
	10"	ACP	1,303	0	0							
	10"	UNK	10	0	0							
12"	DIP	2,469	0	0								
83	12"	DIP	2,469	0	0	0	0	14,718	0.0	0.0000	0.0	132
	6"	ACP	1,788	0	0							
	6"	DIP	453	0	0							
	6"	UNK	6	0	0							
	6"	PVC	84	0	0							
	8"	ACP	659	0	0							
	8"	DIP	3,721	0	0							
	8"	PVC	1,274	0	0							
84	12"	DIP	5,251	0	0	0	0	5,471	0.0	0.0000	0.0	132
	12"	MLS	144	0	0							
	8"	ACP	100	0	0							
	8"	DIP	2,012	0	0							
84	8"	PVC	150	0	0	0	0	5,471	0.0	0.0000	0.0	132
	12"	DIP	2,710	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
85	2"	GALV	758	0	1	0	36	16,896	36.0	0.0036	60.8	10
	4"	ACP	921	0	0							
	4"	UNK	29	0	0							
	4"	ODS	1,849	0	1							
	6"	ACP	2,295	0	1							
	6"	ODS	11,989	0	30							
	8"	ACP	458	0	1							
	8"	DIP	233	0	0							
86A	8"	ODS	2,904	0	2	1	4	31,680	4.5	0.0005	14.3	51
	2"	COP	138	0	0							
	2"	GALV	218	0	0							
	4"	DIP	10	0	0							
	6"	ACP	12,373	0	2							
	6"	UNK	23	0	0							
	8"	ACP	12,826	1	1							
	8"	DIP	1,615	0	0							
	8"	UNK	1	0	0							
	8"	PVC	277	0	1							
	10"	ACP	332	0	0							
	10"	DIP	30	0	0							
	12"	DIP	3	0	0							
	12"	PVC	58	0	0							
86B	4"	ACP	220	0	0	1	11	23,760	11.5	0.0012	27.3	28
	6"	ACP	8,484	1	5							
	6"	DIP	74	0	0							
	8"	ACP	14,685	0	5							
	10"	ACP	2,404	0	1							
	12"	DIP	787	0	0							
86C	12"	PVC	77	0	0	0	15	21,120	15.0	0.0015	31.7	23
	2"	COP	33	0	0							
	2"	GALV	124	0	0							
	4"	ACP	455	0	0							
	4"	DIP	12	0	0							
	6"	ACP	12,214	0	12							
	6"	DIP	26	0	0							
	6"	UNK	7	0	0							
	6"	ODS	28	0	0							
	6"	PVC	429	0	0							
	8"	ACP	7,761	0	3							
	8"	DIP	1,476	0	0							
	8"	PVC	4,336	0	0							
	10"	ACP	107	0	0							
10"	PVC	549	0	0								
12"	DIP	1	0	0								
87A	8"	ACP	449	0	0	0	0	422	0.0	0.0000	0.0	132
87B	2"	GALV	77	0	0	0	0	2,640	0.0	0.0000	0.0	132
	4"	ACP	3	0	0							
	4"	ODS	128	0	0							
	8"	ODS	1,624	0	0							
87C	4"	ACP	768	0	3	0	27	3,907	27.0	0.0027	10.5	59
	4"	ODS	2	0	0							
	6"	ACP	542	0	1							
	6"	ODS	5,734	0	23							
	6"	PVC	104	0	0							
	8"	DIP	37	0	0							
87D	2"	GALV	25	0	3	0	5	6,864	5.0	0.0005	3.4	88
	6"	ACP	1,548	0	1							
	6"	ODS	295	0	1							
	8"	DIP	899	0	0							
	8"	PVC	444	0	0							
88	2"	GALV	1,369	0	1	0	67	38,482	67.0	0.0067	257.8	1
	4"	ACP	3,375	0	2							
	4"	ODS	2,942	0	5							
	6"	ACP	2,587	0	3							
	6"	DIP	32	0	0							
	6"	UNK	9	0	0							
	6"	ODS	17,338	0	49							
	6"	PVC	59	0	0							
	8"	ACP	1,129	0	0							
	8"	DIP	451	0	0							
	8"	ODS	4,164	0	7							
	8"	PVC	21	0	0							
	10"	UNK	2	0	0							
	10"	PVC	1,507	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
89	4"	ACP	3	0	0	0	4	14,088	4.0	0.0004	5.6	74
	4"	ODS	471	0	0							
	6"	ACP	534	0	0							
	6"	DIP	36	0	0							
	6"	ODS	566	0	4							
	8"	DIP	6,067	0	0							
	8"	ODS	794	0	0							
	12"	DIP	4,337	0	0							
90A	2"	GALV	448	0	1	0	10	23,232	10.0	0.0010	23.2	31
	4"	ACP	6,684	0	3							
	6"	ACP	15,661	0	6							
	8"	ACP	3,292	0	0							
	8"	UNK	115	0	0							
	8"	PVC	4,306	0	0							
	10"	UNK	34	0	0							
	10"	PVC	5	0	0							
90B	2"	GALV	82	0	0	0	2	3,168	2.0	0.0002	0.6	121
	4"	ACP	799	0	1							
	6"	ACP	3,601	0	1							
	8"	ACP	80	0	0							
90C	2"	GALV	101	0	1	0	21	16,896	21.0	0.0021	35.5	18
	4"	ACP	945	0	0							
	4"	ODS	3,964	0	5							
	6"	ACP	3,007	0	2							
	6"	ODS	3,857	0	3							
	8"	UNK	30	0	0							
	8"	ODS	4,266	0	10							
	8"	PVC	2,111	0	0							
	12"	DIP	15	0	0							
	12"	MLS	24	0	0							
	12"	PVC	178	0	0							
90D	2"	GALV	175	0	0	0	1	2,112	1.0	0.0001	0.2	127
	4"	ACP	196	0	0							
	4"	UNK	20	0	0							
	6"	ACP	1,494	0	1							
	8"	PVC	444	0	0							
	12"	PVC	5	0	0							
91	2"	GALV	181	0	0	2	17	42,240	18.0	0.0018	76.0	8
	4"	ACP	2,004	0	0							
	4"	DIP	3	0	0							
	6"	ACP	18,397	2	10							
	6"	DIP	29	0	0							
	6"	UNK	68	0	0							
	6"	PVC	272	0	0							
	8"	ACP	10,746	0	5							
	8"	DIP	2,908	0	2							
	8"	PVC	3,502	0	0							
	10"	ACP	447	0	0							
	10"	PVC	722	0	0							
	12"	ACP	27	0	0							
	12"	DIP	1,530	0	0							
	12"	PVC	3,228	0	0							
92	6"	ACP	512	0	3	0	3	2,376	3.0	0.0003	0.7	120
93A	4"	ACP	2,961	0	4	0	25	27,380	25.0	0.0025	68.4	9
	6"	ACP	12,679	0	16							
	6"	UNK	23	0	0							
	8"	ACP	17,611	0	5							
	8"	UNK	2	0	0							
	8"	PVC	1,331	0	0							
	10"	ACP	310	0	0							
	10"	PVC	424	0	0							
	12"	ACP	1,827	0	0							
	12"	PVC	86	0	0							
	14"	ACP	770	0	0							
93B	4"	ACP	1,780	0	2	0	15	38,762	15.0	0.0015	58.1	11
	6"	ACP	23,976	0	8							
	6"	UNK	46	0	0							
	6"	PVC	247	0	0							
	8"	ACP	7,421	0	5							
	8"	DIP	260	0	0							
	8"	PVC	1,326	0	0							
	10"	ACP	870	0	0							
	12"	PVC	70	0	0							

AREA	PIPE SIZE	PIPE TYPE	LINEAR FEET	SERVICE LEAKS	MAIN LEAKS	TOTAL SERVICE LEAKS	TOTAL MAIN LEAKS	PROPOSED LENGTH	WEIGHTED TOTAL	LEAKS PER 1,000-FT	LEAKS PER PROPOSED LENGTH	RANK
93C	2"	GALV	38	0	0	1	13	40,656	13.5	0.0014	54.9	13
	4"	ACP	1,734	0	2							
	4"	UNK	24	0	0							
	4"	PVC	134	0	0							
	6"	ACP	13,564	1	8							
	6"	DIP	468	0	0							
	6"	UNK	38	0	0							
	6"	PVC	405	0	0							
	8"	ACP	9,977	0	1							
	8"	DIP	30	0	0							
	8"	PVC	2,542	0	0							
	10"	ACP	1,833	0	0							
	10"	UNK	3	0	0							
	10"	PVC	59	0	0							
12"	ACP	5,639	0	2								
12"	MLS	4	0	0								
93D	2"	GALV	262	0	0	0	16	32,736	16.0	0.0016	52.4	14
	4"	ACP	1,950	0	1							
	4"	DIP	7	0	1							
	4"	PVC	45	0	0							
	6"	ACP	20,192	0	9							
	8"	ACP	9,756	0	4							
	8"	DIP	192	0	0							
	10"	ACP	220	0	1							
	10"	UNK	14	0	0							
12"	ACP	1,388	0	0								
94	2"	COP	33	0	1	0	1	264	1.0	0.0001	0.0	131
	8"	DIP	271	0	0							
	12"	PVC	2	0	0							
95	8"	ACP	654	0	0	0	0	1,584	0.0	0.0000	0.0	132
	10"	UNK	14	0	0							
	12"	PVC	0	0	0							
96	2	GALV	209	0	0	0	33	5,266	33	0.0033	17.38	43
	4	ODS	104	0	0							
	6	ACP	3,057	0	1							
	6	ODS	2,057	0	32							
8	ACP	18	0	0								